



March 31, 2021

Summit Homes  
120 SE 30<sup>th</sup> St  
Lee's Summit, MO 64082

**RE: Inspection for 4408 SW Alabaster Circle, Lee's Summit, MO 64082 – Permit # PRRES20202107**

On March 26, 2021, a special inspection was performed by Residential Engineering Services, LLC (R.E.S.) at the above referenced property. The purpose of this inspection was to inspect bores drilled into existing floor joist that measured 2" or less from bottom of joist.

**Recommendations:**

- RES recommends installing LSTA18 straps under affected joist.

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

*Joshua Elizondo*

Joshua Elizondo, Project Engineer

Reviewed by,

*Blake Shadid*

Blake Shadid, PE

