

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204449
Address: 114 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, March 31, 2021

Corrective Action Required:

1	Misc	Expose trusses covered patio Nail sheathing per code front bedroom Provide hanger truss above bed 3 door Seal upward penetration top plate rear wall garage Seal penetrations bottom plate under patio window & fireplace Provide HUS26 hangers at girder E1 truss master Provide CS-PF at SGD per plan Provide nuts & washer & tighten anchor bolts garage Tighten anchor bolts bottom plate basement Covered patio shall have 1 roof vent and 4 soffit vents per plan
---	------	--

Comments: