

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192072
Address: 1537 SW ARBOR CREEK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Brandon Kalwei	Passed	Friday, January 03, 2020

Corrective Action Required:
1 Misc 2 PIERS FAILED. NOT ON SOLID ROCK. PROVIDE 36" DEPTH

Comments: