

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204993
Address: 180 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, March 31, 2021

Corrective Action Required:

1	Misc	- PROVIDE RESTROOM SIGNAGE - - PROVIDE 18" VERTICAL GRAB BARS RESTROOMS - -PROVIDE PANIC HARDWARE SOUTH ENTRY DOOR - - PROVIDE OCCUPANT LOAD SIGN -
---	------	--

Comments: