

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Wednesday, March 31, 2021

Informational:	
1	THIRD FLOOR
	-AREAS APPROVED-
	BUILDING C
	SHEAR WALLS IL-A 1ST LAYER: ROOMS 3019,3022-325,3027, 3029-3031
	RC CHANNEL MECHANICAL ROOM CEILINGS 3019-3031,3003-3016
	SHOWER BUILD OUT CEILINGS 3027,3026,3023,3022, 3020, 3006, 3007,3008, 3011, 3012

Informational:  
2 SECOND FLOOR

Informational:

3 FIRST FLOOR

Corrective Action Required:

4	Miscellaneous	-PATCH HOLE AT DWV IN 3028
	Correction	-3026 COMPLETE NAILING PATTERN NORTH AND SOUTH WALLS

**Comments:**