

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203773
Address: 2342 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|-----------|--------------------------|
| All Rough Inspection - Residential | John Morris | Not Ready | Thursday, April 01, 2021 |

Informational:

| | | |
|---|------|-----------------------|
| 1 | Misc | Portal frame approved |
|---|------|-----------------------|

Corrective Action Required:

| | | |
|---|------|---|
| 2 | Misc | <ul style="list-style-type: none">-Provide nail plate protection at DWV top plate penetration, main level bath-Address Removed Section of top plate in pantry-12" oc fastening, stud to stud and abutting studs at intersecting braced walls-Fireblock penetration in wood fire block at garage soffit to wall connection-Anchor bolt required within 12 inches of plate splice, east foundation wall at unused rebar ground-Repair/replace full depth solid blocking over beams Removed/damaged by other trades-Minimum 12" field 6" edge exterior sheathing fastening throughout. ensure fasteners are penetrating studs throughout |
|---|------|---|

Comments: