

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202110
Address: 2931 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, April 01, 2021

Corrective Action Required:

1	Misc	-OBTAIN LAWN IRRIGATION SYSTEM PERMIT -WATER METER LID TO BE EVEN WITH GRADE, MAINTAIN REQUIRED 14"-18" CLEARANCE FROM TOP OF METER TO TOP OF LID
---	------	--

Comments: