- 1	
- 1	
- 1	
- 6	

## **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20201088 Date: April 02, 2021

Project Title: GLOSS NAILS Applicant:

Location:

470 NW CHIPMAN RD, LEES SUMMIT, MO 64086 < NO CONTACT NAME AVAILABLE>

Type of Work: <NO CONTACT INFORMATION AVAILABLE>

Occupancy Group: B

Description: LANDLORD WORK FOR FUTURE

NAIL SALON JAMES FORD

Construction Type: Type IIB (Unprotected) 3809 PINNACEL CIR.
Map Page: LAWRENCE, KS 66049

Primary: (913) 568-2459

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Michael Weissenbach Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule testing.

Alarm Plan Review Reviewed By: Michael Weissenbach Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule testing.

Alarm Plan Review Reviewed By: Michael Weissenbach Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. (Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.