

## ANALYTICAL REPORT

November 13, 2020

Work Order: 1K00980

Page 1 of 3

Report To
John Dimauro City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 11/12/2020 10:35AM Collector: DiMauro, John Phone: (816) 969-1200 PO Number: Routine Analysis

Project : Beemer Construction

Project Number: Napa Valley 4th Plat

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
<b>1K00980-01</b> East Tap				Matrix:Drink Wtr		Collected: 11/12/20 08:10	
Total Coliforms	<1.0 MPN/100ml	1.0	1DK0555	9223B-QT	CLJ	11/12/20 15:40	
E. Coli	<1.0 MPN/100ml	1.0	1DK0555	9223B-QT	CLJ	11/12/20 15:40	
<b>1K00980-02</b> West Tap				Matrix:Drink Wtr		Collected: 11/12/20 08:02	
Total Coliforms	<1.0 MPN/100ml	1.0	1DK0555	9223B-QT	CLJ	11/12/20 15:40	
E. Coli	<1.0 MPN/100ml	1.0	1DK0555	9223B-QT	CLJ	11/12/20 15:40	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.  
220 SE Green Str  
Lees Summit, MO 64063

November 13, 2020

Work Order: 1K00980

Page 2 of 3

## Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications	
9223B-QT in Drink Wtr			
	Total Coliforms	KS-KC,MO-KC	
	E. Coli	KS-KC,MO-KC	
Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2021
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021
MO-KC	Missouri Department of Natural Resources	140	04/30/2021
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

# Keystone

PAGE: 1 of 1

BILLS TO:

NAME:

CO. NAME: Beemer Construction Co.

ADDRESS: 606 SE Central Dr

CITY/ST/ZIP: Blue Springs, MO 64014

PHONE: (816) 229-2266

(816) 229-2266

LAB USE ONLY

Wk Order #: 1800980

**Short Hold:**

Rush:

Temp.

Sample Condition

Sample #

20.

Total Coliform

×

×

Remarks:

1

Time: 10:35

Carroll Jones