



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
205		12/17/20	80181	B	CL	16.1	105.4	14.1	102.4	116.8	8	97	95 / 103	-2 / 2	A
206		12/17/20	80181	B	CL	16.1	105.4	14.5	105.3	120.6	8	100	95 / 103	-2 / 2	A
207		12/17/20	80181	B	CL	16.1	105.4	15.0	102.6	118.0	8	97	95 / 103	-2 / 2	A
208		12/17/20	80181	B	CL	16.1	105.4	15.0	102.4	117.8	8	97	95 / 103	-2 / 2	A
209		12/17/20	80181	B	CL	16.1	105.4	14.7	108.0	123.9	8	102	95 / 103	-2 / 2	A
210		12/17/20	80181	B	CL	16.1	105.4	14.6	103.0	118.0	8	98	95 / 103	-2 / 2	A
211		12/17/20	80181	B	CL	16.1	105.4	16.7	102.7	119.8	8	97	95 / 103	-2 / 2	A
212		12/17/20	80181	B	CL	16.1	105.4	15.8	101.4	117.4	8	96	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
205	Mass Grading: SW Hook Farm Dr STA 24+00	-5.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
206	Mass Grading: SW Hook Farm Dr STA 25+00	-6.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
207	Mass Grading: SW Hook Farm Dr STA 26+00	-6.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
208	Mass Grading: SW Hook Farm Dr STA 27+00	-5.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
209	Mass Grading: SW Hook Farm Dr STA 28+00	-5.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
210	Mass Grading: SW Hook Farm Dr STA 29+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
211	Mass Grading: SW Hook Farm Dr STA 29+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
212	Mass Grading: SW Hook Farm Dr STA 28+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks

Comments

A: Tests results comply with specifications

Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
213		12/17/20	80181	B	CL	16.1	105.4	14.5	102.1	116.9	8	97	95 / 103	-2 / 2	A
214		12/17/20	80181	B	CL	16.1	105.4	15.8	101.6	117.7	8	96	95 / 103	-2 / 2	A
215		12/17/20	80181	B	CL	16.1	105.4	15.8	103.2	119.5	8	98	95 / 103	-2 / 2	A
237		12/21/20	80181	B	CL	16.1	105.4	14.2	106.7	121.9	8	101	95 / 103	-2 / 2	A
238		12/21/20	80181	B	CL	16.1	105.4	14.2	107.2	122.4	8	102	95 / 103	-2 / 2	A
239		12/21/20	80181	B	CL	16.1	105.4	14.7	106.2	121.8	8	101	95 / 103	-2 / 2	A
240		12/21/20	80181	B	CL	16.1	105.4	15.0	101.9	117.2	8	97	95 / 103	-2 / 2	A
241		12/21/20	80181	B	CL	16.1	105.4	15.4	103.8	119.8	8	98	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
213	Mass Grading: SW Hook Farm Dr STA 27+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
214	Mass Grading: SW Hook Farm Dr STA 26+00	-5.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
215	Mass Grading: SW Hook Farm Dr STA 25+00	-5.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
237	Mass Grading: SW Hook Farm Dr STA 24+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
238	Mass Grading: SW Hook Farm Dr STA 24+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
239	Mass Grading: SW Hook Farm Dr STA 25+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
240	Mass Grading: SW Hook Farm Dr STA 26+00	-4.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
241	Mass Grading: SW Hook Farm Dr STA 27+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks

Comments

A: Tests results comply with specifications

Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
242		12/21/20	80181	B	CL	16.1	105.4	15.0	107.1	123.2	8	102	95 / 103	-2 / 2	A
243		12/21/20	80181	B	CL	16.1	105.4	14.7	100.5	115.3	8	95	95 / 103	-2 / 2	A
244		12/21/20	80181	B	CL	16.1	105.4	14.2	105.5	120.5	8	100	95 / 103	-2 / 2	A
245		12/21/20	80181	B	CL	16.1	105.4	14.2	101.8	116.3	8	97	95 / 103	-2 / 2	A
246		12/21/20	80181	B	CL	16.1	105.4	17.8	99.7	117.4	8	95	95 / 103	-2 / 2	A
247		12/21/20	80181	B	CL	16.1	105.4	14.3	102.8	117.5	8	98	95 / 103	-2 / 2	A
248		12/21/20	80181	B	CL	16.1	105.4	17.9	99.9	117.8	8	95	95 / 103	-2 / 2	A
249		12/21/20	80181	B	CL	16.1	105.4	14.3	100.8	115.2	8	96	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
242	Mass Grading: SW Hook Farm Dr STA 28+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
243	Mass Grading: SW Hook Farm Dr STA 29+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
244	Mass Grading: SW Hook Farm Dr STA 30+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
245	Mass Grading: SW Hook Farm Dr STA 31+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
246	Mass Grading: SW Hook Farm Dr STA 32+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
247	Mass Grading: SW Hook Farm Dr STA 31+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
248	Mass Grading: SW Hook Farm Dr STA 30+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
249	Mass Grading: SW Hook Farm Dr STA 32+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks

Comments

A: Tests results comply with specifications

Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
250		12/21/20	80181	B	CL	16.1	105.4	15.6	99.7	115.3	8	95	95 / 103	-2 / 2	A
251		12/21/20	80181	B	CL	16.1	105.4	17.5	100.9	118.6	8	96	95 / 103	-2 / 2	A
252		12/21/20	80181	B	CL	16.1	105.4	15.3	106.7	123.0	8	101	95 / 103	-2 / 2	A
253		12/21/20	80181	B	CL	16.1	105.4	15.9	101.4	117.5	8	96	95 / 103	-2 / 2	A
254		12/21/20	80181	B	CL	16.1	105.4	15.0	103.2	118.7	8	98	95 / 103	-2 / 2	A
255		12/21/20	80181	B	CL	16.1	105.4	18.0	104.2	123.0	8	99	95 / 103	-2 / 2	A
256		12/21/20	80181	B	CL	16.1	105.4	16.4	101.9	118.6	8	97	95 / 103	-2 / 2	A
257		12/21/20	80181	B	CL	16.1	105.4	17.1	100.5	117.7	8	95	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
250	Mass Grading: SW Hook Farm Dr STA 24+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
251	Mass Grading: SW Hook Farm Dr STA 25+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
252	Mass Grading: SW Hook Farm Dr STA 26+00	-3.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
253	Mass Grading: SW Hook Farm Dr STA 27+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
254	Mass Grading: SW Hook Farm Dr STA 28+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
255	Mass Grading: SW Hook Farm Dr STA 24+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
256	Mass Grading: SW Hook Farm Dr STA 25+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
257	Mass Grading: SW Hook Farm Dr STA 26+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks

Comments

A: Tests results comply with specifications

Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
258		12/21/20	80181	B	CL	16.1	105.4	17.5	103.9	122.1	8	99	95 / 103	-2 / 2	A
259		12/21/20	80181	B	CL	16.1	105.4	17.9	101.4	119.5	8	96	95 / 103	-2 / 2	A
260		12/21/20	80181	B	CL	16.1	105.4	14.4	106.2	121.5	8	101	95 / 103	-2 / 2	A
261		12/21/20	80181	B	CL	16.1	105.4	17.8	101.5	119.6	8	96	95 / 103	-2 / 2	A
262		12/21/20	80181	B	CL	16.1	105.4	17.4	103.5	121.5	8	98	95 / 103	-2 / 2	A
299		12/22/20	81840	B	CL-CH	20.8	99.9	19.5	99.4	118.8	8	99	95 / 103	-2 / 2	A
300		12/22/20	81840	B	CL-CH	20.8	99.9	21.0	99.9	120.9	8	100	95 / 103	-2 / 2	A
301		12/22/20	81840	B	CL-CH	20.8	99.9	21.2	100.0	121.2	8	100	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
258	Mass Grading: SW Hook Farm Dr STA 27+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
259	Mass Grading: SW Hook Farm Dr STA 28+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
260	Mass Grading: SW Hook Farm Dr STA 29+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
261	Mass Grading: SW Hook Farm Dr STA 30+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
262	Mass Grading: SW Hook Farm Dr STA 31+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
299	Mass Grading: SW Hook Farm Dr STA 32+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
300	Mass Grading: SW Hook Farm Dr STA 31+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
301	Mass Grading: SW Hook Farm Dr STA 30+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks	Comments
A: Tests results comply with specifications	Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results															
Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
302		12/22/20	81840	B	CL-CH	20.8	99.9	22.5	96.7	118.5	8	97	95 / 103	-2 / 2	A
303		12/22/20	81840	B	CL-CH	20.8	99.9	21.9	100.1	122.0	8	100	95 / 103	-2 / 2	A
304		12/22/20	81840	B	CL-CH	20.8	99.9	21.4	102.3	124.2	8	102	95 / 103	-2 / 2	A
305		12/22/20	81840	B	CL-CH	20.8	99.9	22.0	99.4	121.3	8	99	95 / 103	-2 / 2	A
306		12/22/20	81840	B	CL-CH	20.8	99.9	21.9	95.6	116.5	8	96	95 / 103	-2 / 2	A
307		12/22/20	81840	B	CL-CH	20.8	99.9	21.5	100.3	121.9	8	100	95 / 103	-2 / 2	A
308		12/22/20	81840	B	CL-CH	20.8	99.9	20.7	100.4	121.2	8	101	95 / 103	-2 / 2	A
336		1/12/21	81841	B	CH	23.3	93.2	24.1	89.1	110.6	8	96	95 / 103	-2 / 2	A
Test Information															
Test #	Test Location						Elevation	Reference	Gauge Make / Model / SN / Calibrated				Field Technician		
302	Mass Grading: SW Hook Farm Dr STA 29+00						0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
303	Mass Grading: SW Hook Farm Dr STA 28+00						0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
304	Mass Grading: SW Hook Farm Dr STA 27+00						0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
305	Mass Grading: SW Hook Farm Dr STA 26+00						0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
306	Mass Grading: SW Hook Farm Dr STA 26+00						-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
307	Mass Grading: SW Hook Farm Dr STA 25+00						-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
308	Mass Grading: SW Hook Farm Dr STA 25+00						0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
336	Mass Grading: SW Hook Farm Dr STA 22+00						-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016				Armstrong, Caleb		
Remarks					Comments										
A: Tests results comply with specifications					Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.										



Olathe
1700 East 123rd Street
Olathe,
Phone: 913-829-0078 | Fax: 913-829-0258

Compaction Test Report

Report #: SNG-000007
Test Method: D6938 / T310

Client:

Hunt Midwest
8300 NE Underground Dr STE 100
Kansas City, MO 64161-9736

Project:

020-3102
Hunt Midwest Hook Farms First Plat
Lee's Summit, MO

Test Results

Test #	Retest Of	Test Date	Proctor ID	Method	Soil Classification	Optimum Moisture (%)	Maximum Dry Density (pcf)	In Place Moisture (%)	In Place Dry Density (pcf)	In Place Wet Density (pcf)	Probe Depth (in)	Percent Compaction	Min/Max Comp. (%)	Optimum Moisture Tolerance (%)	Remark
337		1/12/21	81841	B	CH	23.3	93.2	23.7	96.2	119.0	8	103	95 / 103	-2 / 2	A
343		1/12/21	81841	B	CH	23.3	93.2	23.1	92.6	114.0	8	99	95 / 103	-2 / 2	A
344		1/12/21	81841	B	CH	23.3	93.2	24.6	95.2	118.6	8	102	95 / 103	-2 / 2	A
354		1/13/21	81840	B	CL-CH	20.8	99.9	22.1	103.1	125.9	8	103	95 / 103	-2 / 2	A
355		1/13/21	81840	B	CL-CH	20.8	99.9	20.7	102.9	124.2	8	103	95 / 103	-2 / 2	A
361		1/14/21	80181	B	CL	16.1	105.4	17.9	108.0	127.3	8	102	95 / 103	-2 / 2	A
362		1/14/21	80181	B	CL	16.1	105.4	17.6	108.1	127.1	8	103	95 / 103	-2 / 2	A

Test Information

Test #	Test Location	Elevation	Reference	Gauge Make / Model / SN / Calibrated	Field Technician
337	Mass Grading: SW Hook Farm Dr STA 23+00	-2.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
343	Mass Grading: SW Hook Farm Dr STA 22+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
344	Mass Grading: SW Hook Farm Dr STA 23+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
354	Mass Grading: SW Hook Farm Dr STA 22+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
355	Mass Grading: SW Hook Farm Dr STA 23+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
361	Mass Grading: SW Hook Farm Dr STA 33+00	-1.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb
362	Mass Grading: SW Hook Farm Dr STA 33+00	0.0	Grade	InstroTek, Inc. / 3500 / 3008 / 9/9/2016	Armstrong, Caleb

Remarks

Comments

A: Tests results comply with specifications

Tests are "Direct Transmission" (Method A) unless probe depth is noted as "Backscatter". Gauge calibration data on file with the testing agency.

Stewart Legg
Project Manager