

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200719
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Friday, April 02, 2021

Informational:

1 Misc

- NE SLIDING DOOR WALL ONLY OK TO INSULATE & PLYWOOD -

Corrective Action Required:

2 Misc

- FIRE CAULK UPWARD PENETRATIONS TOP PLATE EXTERIOR RESTROOMS & POOL EQUIPMENT ROOM -

- FIRE BLOCKING EXTERIOR RESTROOMS & POOL EQUIPMENT ROOM -

- PROVIDE PROTECTION CONDUCTORS COVERED PATIO -

Comments: