

# Inspection Summary

Permit #: PRSUBD20201709, Development - Subdivision  
Hook Farms 1st Plat  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Sanitary Sewer - Air Test	John DiMauro	Partial	Friday, April 02, 2021

Informational

1 John DiMauro

I observed the psi test for the majority of line1 and all of lines 2 & 3.

Lines 2 & 3 passed psi testing.

Line 1 from MH 1-3 to the end of line passed.

All testing is still required on line 1 from Existing MH to MH 1-3

**Comments:**