Inspection Summary

Permit #: PRSUBD20201709, Development - Subdivision Hook Farms 1st Plat Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:		Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test		John DiMauro	Partial	Friday, April 02, 2021
Informa 1	itional John DiMauro			- , -
	I observed the psi test for the majority of line1 and all of lines 2 & 3. Lines 2 & 3 passed psi testing. Line 1 from MH 1-3 to the end of line passed. All testing is still required on line 1 from Existing MH to MH 1-3			
Sanitary Sewer - Vacuum		John DiMauro	Partial	Friday, April 02, 2021
Informational 1 John DiMauro				
_	I observed the vacuum testing for SS lines 1, 2 & 3. Line 1: Manholes 1-3 through 1-12 passed. Manholes 1-1 & 1-2 still need tested.			
	Line 2: All manholes passed except 2-3. Crew made corrections and plans to teat again in			

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

the future.

Line 3: passed.

Comments: