

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202588  
Address: 2350 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Morris	Failed	Monday, April 05, 2021

Corrective Action Required:

1	Misc	-Fireblock top plate Penetrations in garage -Identify white insulated conductors to be used as current carrying conductors at both points of termination -Fasten fireplace to framing -repair/replace solid blocking over beams where damaged or removed from other trades -Provide outlet box for circuit at future bench in basement -Provide means to access attic space above living area from attic access in garage or provide second access
---	------	---

Comments: