

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210054
Address: 206 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Monday, April 05, 2021

Corrective Action Required:

1	Misc	- PFH PORTAL FRAMING GARAGE ONLY - - HOLDDOWN & HEADER NAILING APPROVED OK TO COVER EXTERIOR - - PROVIDE MIN (1) 5/8 ANCHOR BOLT INSTALLED PER R403.1.6 WITH 2X2X3/16 PLATE WASHER EACH SIDE PER PLAN -
---	------	---

Comments: