

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210081
Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------|
| Final Electrical Inspection - Commercial | Khanh Nguyen | Failed | Monday, April 05, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | NOT READY FOR INSPECTION. LABEL ALL DC RACEWAY; COMPLETE CONNECTIONS TO INVERTERS; COMPLETE BONDING OF ARRAYS; COMPLETE LABELING PER PLAN; REINSTALL ROOFTOP RECEPTACLE OUTLET NEAR AC THAT WAS REMOVED FOR MODULES INSTALLATION; ETC |
|---|------|---|

Comments: