

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204231
Address: 102 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, April 06, 2021

Corrective Action Required:

1 Misc

Address notched trusses garage/master closet
-(Use 3/4" Plywood or OSB per engineered correction, Master closet trusses not addressed at all)
Anchor bolts shall be in middle 1/3 of width of plate in garage
Fire block soffit line in game room
Fire blocking top plate at furr out rec room-Seal gap middle of north wall
Fire block soffit bed closet in basement south end

Comments: