

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210161
Address: 2428 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	John Morris	Partial	Tuesday, April 06, 2021

Informational:

1	Misc	-perimeter surface bonding approved -partial approval of water bond conductor, bonding device will be located in pool drain -partial approval of bonding conductor to equipment pad location
---	------	--

Comments: