

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201709
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	John DiMauro	Partial	Friday, April 02, 2021

Informational:
1 Misc John DiMauro

I observed the psi test for the majority of line1 and all of lines 2 & 3.

Lines 2 & 3 passed psi testing.

Line 1 from MH 1-3 to the end of line passed.

All testing is still required on line 1 from Existing MH to MH 1-3

Comments: