

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201709
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Ronald Paynter	Partial	Tuesday, April 06, 2021

Informational:

1 Misc

We used a 7.37 inch mandrel for the 8 inch sanitary lines. That was manholes 1-5, 1-6, 1-7, 1-8, 1-9, 1-10, 1-11, 1-12, 2-1, 2-2, 2-3, 2-4, 3-1 and 3-2. Still need to mandrel the 12 inch sanitary lines RP 4-6-21

Comments: