

PLANS REVIEW CONDITIONS

Permit No: PRCOM20204497
Project Title: FIREHOUSE SUBS

Location:

111 SE M 291 HWY, LEES SUMMIT, MO 64063

Type of Work:

Occupancy Group: A-2

Description: TENANT FINISH FOR SANDWICH SHOP

**invite planner to final to verify rtu screening

Construction Type: Type IIB (Unprotected)

Map Page:

Date: April 06, 2021

Applicant:

ATRONIC ALARMS INC

8220 MELROSE DR

LENEXA, KS 66214

Primary: (913) 362-0000

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.