

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203376
Address: 1909 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Tuesday, April 06, 2021

Corrective Action Required:

1	Misc	-Connect the GEC to the grounded bus bar where the service grounded conductor is connected to; or install a #4 copper main bonding jumper from the grounding bus bar on the left to the grounded bus bar
---	------	--

Comments: