

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204231  
Address: 102 NW GRADY CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, April 07, 2021

Corrective Action Required:

1 Misc

**\*\*OK TO INSULATE-LEAVE BOTTOM PLATE IN GARAGE EXPOSED**

Address notched trusses garage/master closet

-THE CORRECTIONS MADE AT THE GARAGE TRUSSES ARE NOT PER THE REPORT, THE TRUSSES NOTCHED IN THE MASTER CLOSET ARE NOT REPAIRED OR MENTIONED IN THE REPORT. PROVIDE ENGINEERED LETTER AND CORRECTION FOR TRUSSES IN THE MASTER CLOSET AND AND DOCUMENTATION THAT THE CORRECTIONS MADE TO THE GARAGE TRUSSES IS ADEQUATE

-Anchor bolts shall be in middle 1/3 of width of plate in garage

**Comments:**