

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210673  
Address: 1619 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Wednesday, April 07, 2021

Corrective Action Required:

1	Misc	-CLEAN ALL GRAVEL AND GRAVEL PILE FROM STREET IMMEDIATELY -CLEAN MUD FROM STREET -REPLACE STORM INLET PROTECTION AT STREET, CURRENT PROTECTION HAS DEGRADED AND NO LONGER OFFERING PROTECTION AS DESIGNED
---	------	---

**Comments:**