

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203428
Address: 4405 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, April 07, 2021

Corrective Action Required:

1	Misc	-RESOLVE OUTSTANDING INSPECTION FEES - (4) OCCUPANCIES CURRENTLY, (5) ALL ROUGH INSPECTIONS, ONLY (3) REINSPECTION FEES ADDED -OBTAIN LAWN IRRIGATION SYSTEM PERMIT -BURY SEWER TRACER BOX IN GRADE, ENSURE REMAINS ACCESSIBLE FOR LOCATE -SPLASH BLOCK AT SE CORNER DOWNSPOUT
---	------	---

OK FOR TCO - TCO EXPIRES 4/16/21

Comments: