

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210737
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Robb Popp	Failed	Wednesday, April 07, 2021

Corrective Action Required:

1	Miscellaneous Correction	Complete pool steel for perimeter surface bond, provide water bond, pool shell (4) points to be equally spaced, and jumper to equipment pad
---	--------------------------	---

Comments: