

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210492
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Michael Harkins	Partial	Wednesday, April 07, 2021

Corrective Action Required:

1	Misc	Install permanent landings and stairs.
		Connect smokes in 3-4 (west trailers) mount all fire extinguisher.
		Ok for class on Monday April 5th with temp stairs and landings.

Comments: