## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20202246 Address: 1195 NW VIEW HIGH DR, LEES SUMMIT, MO 6408111904 NW CHIPMAN RD, LEES SUMMIT, MO 6408111800 NW CHIPMAN RD, LEES SUMMIT, MO 6408111906 NW CHIPMAN RD, LEES SUMMIT, MO 640811201 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Water Line - Construction Inspection		John Jackson	Partial	Wednesday, April 07, 2021
Inform	national:			
1	Misc	4/1/21 Thursday Contractor ( Clarkson - Gregg crew ) as reported and observed by me KCMO water main run through Lee's Summit property started at Sta. 7+07.00 and runs to Sta. 19+75.00. Yesterday contractor installed 8" DIP from Sta. 7+07.00 to Sta. 11+50.00. 1 fire hydrant assembly and 4x45* bends.		
Inform	national:			
2	Misc	4/5/21 Monday Contractor ( Clarkson - Gregg crew ) 4/1/21 Thursday installed 250' of 8" DIP from Sta 11+00 to Sta 13+50. Install 2 X 45 bends and 1 Lee's Summit Hydrant Line B.		
Inform	national:			
3	Misc	250' of DIP from Sta 2 Sta 13+96 & 3/8" valv 15+47. Contractor poured 4/	L3+50 to 16+00 on Line B. es around the Sta. Aalso	londay installed approximately 8"X8"X8" Tee was installed @ o installed Fire Hydrant @ Sta ind hydrant and bends and n of 8" DIP on line B.
Inform	national:	č		

4 Misc 4/7/21 Wednesday Contractor ( Clarkson - Gregg crew ) 4/6/21 as-per pre field stakes approximately 300 8" DIP was Installed. Contractor was at another location and inclement weather (rain) at site.

Comments: