

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, April 07, 2021

Informational:	
1	THIRD FLOOR
	-AREAS APPROVED-
	BUILDING C
	RC CHANNEL MECHANICAL ROOM CEILINGS 3019-3031, CORRIDOOR CEILING AND 24" AT WALL
	SHOWER BUILD OUT CEILINGS 3027,3026,3023,3022, 3020, 3006, 3007,3008, 3011, 3012
	ROCK BEHIND SHOWERS 3019-3031
	RC CHANNEL ROOMS 3019-3020, 3022-3031

	BUILDING A
	RC CHANNEL MECHANICAL ROOM CEILINGS 3003-3016

Informational:	
2	SECOND FLOOR
	-AREAS APPROVED-

	BUILDING C:
	MECHANICAL ROOM CEILINGS 2019, 2020, 2022, 2024-2031

Informational:	
3	FIRST FLOOR
Corrective Action Required:	

4	Miscellaneous Correction	3021- COMPLETE RIDGE VENT/ ROOF
---	-----------------------------	---------------------------------

Comments: