

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Partial	Thursday, April 08, 2021

Corrective Action Required:

1	Misc	: 4TH & 3RD FLOOR REQUIRED INSPECTIONS : - STAIRWAYS, CORRIDORS, ELECTRICAL & IT ROOMS - - 442 DECK RAIL SHALL WITHSTAND 200 LBS FORCE - 461 (ADA UNIT) THE WORK SURFACE SHALL BE 34" INCHES MAXIMUM ABOVE THE FLOOR (1103.12.3.2 PER ICC A117.1-2017) - STROBES, GRAB BARS, THRESHOLD SGD, INSULATE PIPES UNDER SINKS - - 366 REPAIR DRYWALL CEILING LIVING ROOM & MASTER BATH -
---	------	--

Comments: