

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210124
Address: 1526 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, April 08, 2021

Corrective Action Required:

1	Misc	-SET INTERIOR DRAIN TILE, IF NO SUMP PUMP WITH WALKOUT DRAIN TILE MUST DISCHARGE TO DAYLIGHT WITH POSITIVE SLOPE
---	------	---

Comments: