

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200811
Address: 3561 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 640823561 SW MARKET ST, LEES SUMMIT, MO 64082

RELEASED FOR STOCKING AND TRAINING ONLY

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Thursday, April 08, 2021

Corrective Action Required:

1	Misc	-PARKING LIGHT POLE GROUND ROD CONNECTION -SPARK RINGS AT RECEPTACLES ON ALL COMBUSTIBLE SURFACES NOT FLUSH WITH SURFACE -BOND AT WATER LINE ACROSS FROM BACKFLOW VALVE -COMPLETE BOX/CONDUIT INSTALLATION AT SALES FLOOR, SOUTH WALL -GFCI RECEPTACLE AT CUSTOMER SALES FLOOR BATHROOM NOT TRIPPING WHEN TESTED
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	Released to set up, stock inventory and train staff. Not allowed to open for business to the public.
---	--------------------------	--

Comments: