



PLAN REVIEW CONDITIONS

April 08, 2021

LATONA ARCHITECTS
1600 GENESSEE , SUITE 353
KANSAS CITY, MO 64102

Permit No: PRCOM20211645
Project Title: OUR LADY OF THE PRESENTATION - ENTRANCE CANOPY
Project Address: 150 NW MURRAY RD, LEES SUMMIT, MO 64081
Parcel Number: 62130010800000000
Location: PRESENTATION PARISH LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: ASSEMBLY FOR WORSHIP, RECREATION OR AMUSEMENT
Description: NEW ENTRANCE CANOPY AT EXISTING CHURCH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied.

(Verified At Inspection)

Provide exterior emergency lighting.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.