

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203773
Address: 2342 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Friday, April 09, 2021

Informational:
1 Misc Portal frame approved
Corrective Action Required:
2 Misc

-Minimum 12" field 6" edge exterior sheathing fastening throughout. ensure fasteners are penetrating studs throughout. Master closet

Comments: