

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204249
Address: 118 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Friday, April 09, 2021

Corrective Action Required:

1 Misc

-Provide full depth solid blocking, cantilever coat closet at entry
-nail braced wall panels per code, garage & front bed room top of sheathing is below top plates.

Comments: