

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203479
Address: 1634 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Robb Popp	Not Ready	Friday, April 09, 2021

Corrective Action Required:

1	Misc	-Protect wardflex entering fireplace enclosure -Secure wardflex at fireplace -Bond metallic gas line per code
---	------	---

Comments: