

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202213
Address: 3221 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Passed	Friday, April 09, 2021

Informational:
1 Misc Forms were placed and aggregate was present, but still needs to compacted. Also needs to remove piping underneath the sidewalk. Talked with Tim about those issues along with sidewalk finish and cure requirements. RP 3-30-21

Informational:
2 Misc Finished sidewalk meets LS and ADA specs. RP 4-9-21

Comments: