

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210199
Address: 1740 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Not Ready	Monday, April 12, 2021

Corrective Action Required:

1	Misc	- PROVIDE BOCA PLATES BACKSIDE OF RESTROOMS - - NAIL BOTTOM PLATE AT PLATE BREAK NEAR RESTROOMS -
---	------	------------------------------------------------------------------------------------------------------

Comments: