

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20202889
Address: 3100 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Monday, April 12, 2021
Inspected By: Patrick Schonfeldt
Expiration Date: 4/26/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Monday, April 12, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -splash blocks at all downspout and sump pump locations, minimum 36" discharge from foundation
---	------	---

OK FOR TCO - TCO EXPIRES 4/26/21