

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204750
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Passed	Monday, April 12, 2021

Informational:
1 Misc - 3RD PARTY FOOTING BY DEREK PEREZ @ RES SIGNED & SEALED BY BRADLEY HUXOL -
- UFER LOCATED IN CENTER OF SOUTH (REAR) GARAGE FOUNDATION WALL -

Comments: