

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Monday, April 12, 2021

Informational:

1 THIRD FLOOR

-AREAS APPROVED-

BUILDING C

RC CHANNEL MECHANICAL ROOM CEILINGS 3019-3031, CORRIDOOR CEILING
AND 24" AT WALL

SHOWER BUILD OUT CEILINGS

3031,3030,3029,3028,3027,3026,3025,3024,3023,

3022, 3020, 3006, 3007,3008, 3011, 3012,3018,

ROCK BEHIND SHOWERS 3019-3031

RC CHANNEL ROOMS 3019-3020, 3022-3031,

3003-3016,

: below require corrections :

- 3020 add screws 8" OC -

- 3021 add screws 8" OC -

- 3022 add screws 8" OC -

BUILDING A
RC CHANNEL MECHANICAL ROOM CEILINGS 3003-3016

Informational:

2 SECOND FLOOR -AREAS APPROVED-

BUILDING C:
MECHANICAL ROOM CEILINGS 2019, 2020, 2022, 2024-2031

Informational:

3 FIRST FLOOR

Corrective Action Required:

4 Miscellaneous 3021- COMPLETE RIDGE VENT/ ROOF
Correction

Comments: