

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200878
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Tuesday, April 13, 2021

Corrective Action Required:

1 Misc

Straw wattles at south west corner of property is not keeping silt and debris on the property. Immediate clean up of city sidewalk along River Run Drive is required from the south west corner of the property to the corner of 27th street, including removing the debris from the storm water inlet on River Run Drive. If this issue is not resolved within 48 hours, the city will abate the condition and bill the permit holder.

Comments: