



April 12, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of non-continuous deck post for Lot #50 Woodside Ridge – 210 NW Joshua Dr. Dr. Lee's Summit, MO 64081 – Permit # PRRES20204544

This letter addresses the non-continuous posts for deck and patio covering for Lot # 50 Woodside Ridge.

The revision shall be as follows:

- Install (2) 16-gauge ST12 Simpson galvanized straps per post per manufacturer's specifications on both posts for deck and patio covering.
- Install with 16d common nails or #10 x 1-1/2" Strong-Drive SD screws.
- Straps shall be centered over post cut and installed on opposite sides of post.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

