

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203376
Address: 1909 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, April 14, 2021

Corrective Action Required:

1	Misc	-Fb bedroom wall from roof (wall above great room I beam) **The wall is still open to the roof space. Use the same 1/2" wood strip to close off the top of the wall **OK TO INSULATE
---	------	--

Comments: