

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202276
Address: 4712 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, April 14, 2021

Corrective Action Required:

1	Misc	-Fb wall from fur down ceiling space at basement closet **not done. The fur out exterior wall is still open to the fur down ceiling space and the I beam web space
---	------	---

**4/14-Re-inspection fee assessed

Comments: