

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210737
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Wednesday, April 14, 2021

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	4-14-21 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

-Street clean up required immediately. Clean dirt and debris from sidewalk and street and provide silt fence to prevent mud from entering sidewalk or street.

Comments: