

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210737  
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Robb Popp	Partial	Wednesday, April 14, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Bonding for shell, (4) points, perimeter surface, ladder and handrail sleeves -No water bond present
---	--------------------------	--

**Comments:**