

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20193374
Address: 2028 NE BLUESTONE DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, April 14, 2021
Inspected By: Khanh Nguyen
Expiration Date: 5/14/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Wednesday, April 14, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -As-graded plot plan is required
-Clear out obstruction at the rear storm inlet and install silt fence around
-Provide min 6" clearance from siding to grade at north side
-Provide landing outside escape well window and install ladder
-Add more support for the AC lines and exhaust pvc per installation manual
**leave the manual on site for the AC. Support furnace 2" pvc at max 5 ft interval |
|---|------|--|