

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW
OLIVE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Joe Starlin	Partial	Wednesday, April 14, 2021

Informational:

1 Misc

4-14-21 12:13pm testing A5 to A4. The gauge is at 4.0 This section has passed. We are now testing from A-4 to A-3. This section has passed. We are now testing from A-3 to A-2. This section has failed at this time. 3pm They set up from manhole A-2 to A-1. It has passed.

Comments: