

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202580
Address: 1316 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|---------------------------|
| Occupancy Inspection - Codes Residential | Khanh Nguyen | Failed | Wednesday, April 14, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Expose sewer manhole at front -Final grade, sod, downspout and sump pump extensions -Paint gas service piping to protect against corrosion -Provide landings outside basement escape windows -Provide min 1.5" space around the deck stair handrail -Screw the basement exterior door embedded brace into studs -Provide AFCI protection for disposal & dishwasher outlet. Label breaker appropriately |
|---|------|---|

Comments: